Member Generation: Present and Future OPALCO

Board Meeting May 2021

Rates Review: Timeline

May 2021	Member Ge
June	Staff Analys
August	Guernsey C
September	Discussion
Late September	Solar Town
October	Rate Optio
November	Budget and
December	2022 Rate
January	Rate Imple

- eneration Trends and Modeling
- 'SİS
- Cost of Service Analysis (COSA) review
- of Rate Options
- Hall member feedback
- ns Review
- d 2022 Rate Proposal (first read)
- Structure (second read)
- mentation





Member Generation: Present and Future

2020 Member Generation Analysis

Net-Zero Solar Example

Agenda

Understanding the Present

Thinking about the Future

Discussion




2020 Member Generation Analysis






Typical Member Solar + Storage Configuration



Home or Business




OPALCO Grid





OPALCO Member Generation Trends: Installations, Capacity, Production





Total member generation capacity and production grew at 39% last year, with a five year average growth rate of 26%.

Installations grew at 44% last year, with a five year average growth rate of 22%.

Since 2000, retail solar cost has fallen dramatically, but in recent years price in SJC has stabilized in \$3 per watt range, unsubsidized. OPALCO community solar can be built out for less that \$2 per watt, due to economies of scale.







OPALCO 2020 Resource Mix: BPA, Energy Efficiency, Member Generation, Community Solar


- ----

2020 Energy Resource Mix



BPA Sold (217 million kWh) Energy Efficiency (14 million kWh) Member Renewables (3.6 million kWh) Community Solar (.5 million kWh)

Member Renewables (solar, wind, micro-hydro)



55% of member production went to reducing member's personal load (self), with remaining 45% exported to the grid, mostly during sunny summer months when load is low and insolation is high.










Monthly Energy Sales: 2020 Reference Load



217 million kWh Annual BPA Sold

<u>Notes</u>


- Reference Load based on 2020 system load from all members (residential, commercial, etc.)
- Load typically doubles in winter, compared to summer
- 18,882 kWh average annual load per typical member (residential and commercial)







Member Energy Consumption: BPA Sold + Member Self Solar



Energy (kWh)


219 million kWh Annual Consumption 217 million kWh Annual BPA Sold

Notes

- Member generators produced about 2 million kWh of solar for internal use (not exported), which reduced their apparent load.
- Member solar production self solar (before export) is added to BPA sold to get total member <u>consumption</u> (red line)



Monthly Energy Sources



Energy (kWh)

14 million kWh annual energy efficiency

2 million kWh annual member generation exported 217 million kWh annual BPA sold





Monthly Averages Obscure Critical Details


Careful!







2020 Average Member Daily Load: Residential and Commercial



1,217 kWh Annual Energy Efficiency Savings 18,882 kWh Annual Load for typical member

<u>Notes</u>


- Reference Load based on 2020 system load from all members (residential, commercial, etc.)
- Member load typically doubles in winter.
- Energy Efficiency improvements have reduced load by 6%







2020 Average Member Daily Load: Non-solar and solar members




In 2020, about 420 member generators produced an average of about 10,000 kWh each, reducing *their load by* 34%

18,882 kWh annual regular non-solar member

12,450 kWh annual solar member

Notes


- Winter solar production is about 20% of summer.
- Member load is mostly met using BPA, but a small and steadily increasing amount of the load is met using exported member solar, especially on sunny summer days.
- A typical 2020 solar member will import energy from the grid about 80% of the time - during nights, gray days, and especially in winter.
- Typical 2020 solar members export solar about 20% of the time, mostly on sunny summer days.














2020 Total System Daily Load: Regular and Solar Members




Notes


- While solar member annual load is reduced by 34%, since there are only 422 members (3.7% of members), the impact on total load is minimal (1.3% reduction).
- Member load typically doubles in winter.

Load Share	Members	Members %
Total Members	11,500	100%
• Non-Solar	11,078	96%
• Solar	422	4%

6 million kWh Annual Solar Member Load


211 million kWh Annual Regular Member Load







2020 Daily Energy Sources: BPA, Community Solar and Member Generators



2020 Daily Load (MWh)







2020 OPALCO Member Generation: Import/Export Balance

Member generators are always using the grid, either importing or exporting energy. The OPALCO grid is increasingly transactional, helping members to buy and sell energy, as needed.

Annual Energy Import/Export

Import 80%

Export 20%

• A typical member generator will produce more solar in the summer than they need, and will export it to the grid, for billing credit, offsetting winter, when solar production is 20% of summer.

• Even though they produce a good portion of what they consume, they depend on the grid to firm their solar - during nights, gray days, and especially in winter.

• A typical member generator will import energy from the grid about 80% of the time - during nights, gray days, and especially in winter (chart at left).





Net-Zero Solar Member (NZSM) Analysis

to explore potential problems and opportunities as member generation market share increases

net-zero is a common starting point for initial sizing a member solar project



Modeling Impact of Member Solar as Market Share Increases

What-If Model: Explore impact if 50% of OPALCO members have net-zero solar (generate what they consume annually)

Impact Analysis: load, generation, load shape, grid impact


Data: 2020 <u>hourly</u> system load, member generation, and Decatur Community Solar generation to establish reference load and solar generation <u>shape</u> for all members (residential, commercial, etc.)



Note.

The impact presented below is generally linear - regardless of number of members or amount of production.

It scales.





What is a net-zero solar member (NZSM)?

A member that produces as much electric energy as they consume annually, typically using a solar array.

NZSM Annual Energy Import/Export



Export 27%

• The average OPALCO member (residential/commercial) consumes about 18,800 kWh per year, requiring a net-zero solar array of about 18 kW.

• A typical NZSM will over-produce solar in the summer, for billing credit, offsetting winter, when solar production is 20% of summer.

• Even though they produce as much as they consume yearly, they depend on the grid to firm their solar - during nights, gray days, and especially in winter.


• A typical NZSM will import energy from the grid about 73% of the time during nights, gray days, and especially in winter (chart at left).







Monthly Energy Sales: 2020 and 50% Net-Zero Solar Model Load




Energy (kWh)

Notes

217 million kWh Annual 2020 Reference **180 million kWh Annual NZSM Model**

- Modeling 50% of OPALCO members have Net-zero solar system
- Solar output reference based on Decatur community solar array, scaled to member level
- Net-zero solar members reduce their OPALCO load, reducing total annual kWh sales by 37 million kWh
- Load reduction is weaker in winter when solar output is 20% of summer









Monthly Averages Obscure Critical Details

Careful!














Day Average Hourly System Load: NZSM member


















Day Average Hourly System Load: Regular and NZSM Member










Day Average Hourly System Load: Combined - Regular + NZSM Member










Day Average Hourly System Load: 2020 Reference Load







Daily Averages Obscure Critical Details


Careful!









Day Average Hourly System Load: No Solar Export, With Annual kWh Sold












Hourly Load and Solar Production Around Winter and Summer Solstice

Typical NZSM Hourly Consumption and Generation Mix (kWh)



During winter solstice, solar insolation is at a minimum.

During summer solstice insolation is at a maximum.

<u>Notes</u>

- System load typically doubles in winter.
- Winter solar is about 20% of summer.
- A typical NZSM will import energy from the grid about 73% of the time - during nights, gray days, and especially in winter.
- Net-zero members export solar about 27% of the time, mostly on sunny summer days.
- Note cloud strikes on 5 and 9 June late afternoon, and a brief solar export on 15 December mid-day.




Climate Impact: Increased Fires Reduce Solar Output

WILDFIRES Solar power plunges as smoke shrouds Calif.

Peter Behr, E&E News reporter Published: Friday, September 11, 2020



Decatur Array Output During 2020 Regional Fire Season






Load Shape

Focusing on impact on load shape, with and without NZSM solar export



Typical Current OPALCO Hourly Winter System Load Example (MW)



Cold mornings typically have a strong primary peak (members waking up, turning on the heat) compared to secondary peak in evenings.


Time of Day Across 15 Days

10





2020 Typical Member Hourly Load Around Winter and Summer Solstice




Winter load is typically double of summer load.


Notes


- Cold mornings typically have a strong primary peak, as members wake up and turn on the heat, and take a shower.
- A secondary peak occurs in evenings as people return home, turn up the heat and turn on the lights.
- The secondary peak is less pronounced in summer with longer daylight, minimal heating, and morning showers drawing on hot water, keeping the primary peak stronger.












Monthly Energy Sales: 2020 and 50% Net-Zero Solar Model Load



Energy (kWh)


<u>Notes</u>

217 million kWh Annual 2020 Reference 180 million kWh Annual NZSM Model

- Winter load is typically double of summer load
- Net-zero solar members reduce their OPALCO load, reducing total annual kWh sales by 37 million kWh
- Load reduction is weaker in winter when solar output is 20% of summer




Load Shape Analysis: Total NZSM System Load, No Solar Export




Week of 9 March 2020 was a cold clear sunny week, with dramatic load changes as the sun rises and sets

<u>Notes</u>

- On sunny days, as sun rises, NZSM load <u>rapidly</u> falls to zero.
- As sun sets, load <u>rapidly</u> increases to normal regular non-solar member load.
- This rapid decrease/increase in demand is similar to California's Duck Curve problem, where firming resources need to quickly track the changes to maintain stable power and protect sensitive member appliances.
- As more OPALCO members adopt solar, rapid load changes increase in frequency and intensity.




Load Shape Analysis: 2020 Reference load, NZSM Model System Load (with and without export)




Notes

- The green line is the 2020 reference load of OPALCO's system.
- The yellow line is the system load in the NZSM model (50% regular members + 50% NZSM members). The reduction from 2020 load is due to NZSM self generated solar <u>only</u>. No NZSM export is considered.
- The red line is the system load in the NZSM model, with NZSM export.
- Note the shear fall and rise of the yellow and red line load. The next slide explores those rapid changes.













Load Shape Analysis: Avg, Max Up, Max Down Hourly Change for 2020 Reference, NZSM No Export and NZSM Export



Notes

- The average, max up and max down change in hourly load are displayed for 2020 Reference, NZSM no export, and NZSM with export.
- The yellow line is the average <u>change</u> in system load, in a given hour, each day of the year, for each scenario.
- The green line is the maximum change up.
- The red line is the maximum change down.
- Note the increasingly amplified movements - load changing downward as the sun rises, and load changing upward as the sun sets.
- The NZSM export chart shows further amplification of load changes, due to export of solar energy to grid, offsetting firm BPA with intermittent solar. The rapid downward movements are due to cloud strikes.




















Load Shape Analysis: Seasonal View of Hourly Change for 2020 Reference, NZSM No Export and NZSM Export





Notes

- Scattergraph of over 26,000 hourly data points for 2020 Reference Load, and NZSM with and without export.
- Worst case hourly change happens in shoulder seasons, when days are cold (bigger load) but clear (more solar).
- Export case is most dramatic because, on sunny days, it can literally take a cold morning peak load and drive it to zero, in a matter of an hour or two, as the sun rises on a clear day. And the reverse happens at the end of the day as the sun sets, and clear cold night rushes load back to peak.
- 2020 Reference Load is typical confined to movements within +/- 5 MW. NZSM has over 600 events that are triple that range.












Load Shape Analysis: Seasonal and Hourly View of Hourly Change for 2020 Reference, NZSM No Export and NZSM Export





Notes

- Scattergraph of over 26,000 hourly data points for 2020 Reference Load, and NZSM with and without export.
- Worst case hourly change happens in shoulder seasons, when days are cold (bigger load) but clear (more solar).
- Export case is most dramatic because, on sunny days, it can literally take a cold morning peak load and drive it to zero, in a matter of an hour or two, as the sun rises on a clear day. And the reverse happens at the end of the day as the sun sets, and clear cold night rushes load back to peak.
- 2020 Reference Load is typical confined to movements within +/- 5 MW. NZSM has over 600 events that are triple that range.














Load Shape Analysis: BPA Load, Hourly Change in Load



Notes

- The green line is the 2020 reference load of OPALCO's system.
- The yellow line is the system load in the NZSM model (50% regular members + 50% NZSM members). The reduction from 2020 load is due to NZSM self generated solar <u>only</u>. No NZSM export is considered.
- The red line is the system load in the NZSM model, with NZSM export.
- Note the shear fall and rise of the yellow and red line load. The next slide summarizes the annual impact of those rapid changes.








Load Shape Hourly Change: Statistical Analysis Summary

Hourly Load Change	2020 Reference	NZSM no export	NZSM with export
Standard Deviation	1.5 MW	2.6 MW	4 MW
Max Spike Up	6 MW	16 MW	26 MW
Max Spike Down	-11.5 MW	-19 MW	-31 MW
Count > 2020 Up Max		286	527
Count > 2020 Down Max		22	112


<u>Notes</u>

- NZSM hourly load has over 639 spikes larger than than any that occurred in 2020.
- Climate Impact: reducing stream flow, increasing fire season, etc. all increase day ahead market firming resources risk.
- Climate Impact: Fluctuation of hydro system with climate impact on seasonal flow, especially summer time.
- Buying on short-term market (Energy Imbalance Market (EIM)and Energy Day Ahead Market (EDAM)), to firm spikes in load, becomes very unpredictable and expensive.
- Will require rethinking protection schema given large bi-directional power spikes.






Export and Over-Generation



Representational Monthly Energy Sales: Generation to meet Net-Zero Model Load




Energy (kWh)


Notes

217 million kWh Annual 2020 Reference **180 million kWh Annual NZSM Model**

- Goal: use member exported solar <u>first</u>, and backfill with mainland power
- Winter is typically 92% BPA, 8% solar
- Summer is typically 65% BPA, 35% solar
- During summer days, net-zero solar production exceeds member load so is mostly exported to OPALCO grid, 72% is overgeneration, exceeding what we need to meet total system load.
- **Over-Generation:** Summer daily solar export exceeds total system daily load, so is either: - curtailed,
 - sold to mainland at market rates,
 - stored in longterm storage (e.g. hydrogen fuel cell)
- Though summer is net solar export, at night and during cloudy days, BPA is needed to firm solar (see previous hourly slides)












Daily Energy Mix: BPA, NZSM with Solar Export and Over-Generation





<u>Notes</u>

- NZSM Purchased: Is used to serve system load <u>first</u>.
- BPA Purchased: Is used to backfill system load when member solar export is not enough.
 - Over-Generation: Summer daily solar export exceeds total system daily load, so is either: - curtailed,
 - sold to mainland at <u>market</u> rates,
 - stored in longterm storage (e.g. hydrogen fuel cell)




NZSM Purchased

22 million kWh







Day Average Hourly System Load: 2020 and NZSM Model




Day Average Hourly System Load: NZSM Load



NZSM Hourly Generation Mix: NZSM Purchased




NZSM Hourly Generation Mix: BPA Backfill




Power (MW)

NZSM Hourly Generation Mix: BPA, NZSM Purchased




NZSM Hourly Generation Mix: BPA, NZSM Purchased, Over-Generation





Daily Energy Mix: 2020 Reference and NZSM Model Summary



BPA Purchased 158 million kWh

NZSM Over-Generation

50 million kWh


Summer daily solar export exceeds total system daily load, so is either:

- sell to BPA?
- stored in longterm storage for winter (e.g. hydrogen fuel cell, >50% loss)

NZSM Purchased for resale to regular members 22 million kWh



NZSM Model Summary



• 5,750 NZSM members, 5,750 regular members (no generation)

 Resultant Energy Mix to serve 180 million kWh load - BPA 88% (158 million kWh) - Local Solar 12% (22 million kWh)


 NZSM members will collectively produce 109 million kWh annually - 37 million kWh for self (reducing total annual kWh sold to 180 million) - 22 million kWh resold to OPALCO for regular member load, displacing BPA - 50 million kWh over-generation (curtailed?, sold to BPA?, stored for winter?)


 NZSM members collectively would have 110,000 kW of solar capacity - covering 660 acres of surface, mostly rooftop - 19 kW dc capacity each (average among residential and commercial members)


• NB: Over-generation starts to happen after 12.5% of members are NZSM (1,438).
















































What portion of the year does NZSM solar provide power?

Northwest has half the capacity factor of the Southwest. Longer nights in winter during peak load. Lower loads in summer during peak sun.

Dark 56%






DISCUSSION

pros and cons local resilience reliability over-generation curtailment longterm storage sell to BPA load shape load reduction how to maintain firm power, and manage cost of power how to balance needs of solar and non-solar members

wholesale reliability ² Curtailment BPA demand charges Duck Curve Duck Curve production credit energy costs 9 b

grid modernization requirements to support increased load spikes and bi-directional











Rates Review: Timeline

May 2021	Member Ge
June	Staff Analys
August	Guernsey C
September	Discussion
Late September	Solar Town
October	Rate Optio
November	Budget and
December	2022 Rate
January	Rate Imple

- eneration Trends and Modeling
- 'SİS
- Cost of Service Analysis (COSA) review
- of Rate Options
- Hall member feedback
- ns Review
- d 2022 Rate Proposal (first read)
- Structure (second read)
- mentation

















Billed Versus Actual Cost as a % of Total Cost

Typical OPALCO Residential Bill

Usage

Charge

100%

90%

80%

70%

60%

50%

40%

30%

20%

10%

0%

1954

Rule of Thumb Bill = Rates x Weather

top heavy -leads to over charging in cold winters and undercharging in warm winters

> Facility Charge

2 8 4 S 0 201 201 201 201 201 201 201 201

Actual OPALCO Costs

BPA Electricity Cost

Operations/Facility Cost

For decades, the Facility <u>Charge</u> has only recovered a fraction of the *actual* Facility <u>Cost</u>.

The bottom line is that we must cover the cost to run our operations. Historically, we have done so through energy (*kWh*) usage charges. With warmer temperatures, usage goes down and that creates revenue volatility for the Co-op. The new rate structure will gradually correct this weak link in the system so the Co-op can sustain the level of electric service that members demand.

1989

1996

2003

2010

2017

1982

1968


1961

1975







OPALCO Facility Charge Analysis








Typical Monthly Residential Energy Use: All Electric Home, Three Rates **Typical All-Electric Home Monthly Bill: 2 Rates** Avg. bill = \$146/month, \$1,757/year














Side-effects of local energy production: Economics and Subsidies



Source: OPALCO, PVWatts


Example Notes & Assumptions







M.O.R.E. Member Generator Incentives and Subsidies



Notes:

M.O.R.E. member total kWh generated drives WA production and and M.O.R.E. incentive payments.

OPALCO net metering credit based on <u>net</u> kWh after usage. Net metering rate is retail (versus BPA wholesale), hence <u>all</u> members pay subsidy to member generators.

Typically solar member generators shift excess summer production to winter consumption, using the grid as a seasonal battery.

OPALCO receives, administers and distributes WA and M.O.R.E. incentives.

WA incentive payments are subject to \$100,000 WA annual cap.

OPALCO Member Generator Incentives 67



